

2024 Consumer Confidence Report

Este informe contiene información muy importante sobre su agua para beber. Favor de comunicarse Jacumba Community Services District a (619) 766-4359 para asistirlo en español.

Water System Information

Water System Name: Jacumba Community Services District

Report Date: 7/1/2025

Type of Water Source(s) in Use: Groundwater

Name and General Location of Source(s): Well 4 is west of the town of Jacumba. Well 7 & 8 are on the west end of the town of Jacumba. Water was provided by Well 7 in 2024. Wells 4 and 8 were not used.

Drinking Water Source Assessment Information: A copy of the Drinking Water Source Assessment for Well 4 & 8 can be viewed at the district office. Well 4 is most vulnerable to flooding, and Well 8 is most vulnerable to contamination via septic systems.

Time and Place of Regularly Scheduled Board Meetings for Public Participation: Board meetings are held at the Jacumba Public Library (44605 Old Hwy 80, Jacumba, CA 91934) on the 4th Tuesday of every month at 6pm.

For More Information, Contact: Emilio Gonzalez, Lead Operator (619) 766-4359

About This Report

We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 to December 31, 2024, and may include earlier monitoring data.

Terms Used in This Report

Term	Definition
Maximum Contaminant Level (MCL)	The highest level of a contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically and technologically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.
Maximum Contaminant Level Goal (MCLG)	The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (U.S. EPA).
Maximum Residual Disinfectant Level (MRDL)	The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Term	Definition
Maximum Residual Disinfectant Level Goal (MRDLG)	The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
Public Health Goal (PHG)	The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.
Regulatory Action Level (AL)	The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.
ND	Not detectable at testing limit.
N/A	Not applicable
ppm	Parts per million or milligrams per liter (mg/L)
ppb	Parts per billion or micrograms per liter (µg/L)
NTU	Nephelometric turbidity units
µS/cm	Microsiemens per centimeter

Sources of Drinking Water and Contaminants that May Be Present in Source Water

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, that can be naturally occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, that are byproducts of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- Radioactive contaminants, that can be naturally occurring or be the result of oil and gas production and mining activities.

Regulation of Drinking Water and Bottled Water Quality

In order to ensure that tap water is safe to drink, the U.S. EPA and the State Board prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. The U.S. Food and Drug Administration regulations and California law also establish limits for contaminants in bottled water that provide the same protection for public health.

Additional General Information on Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the U.S. EPA's Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. U.S. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

Lead-Specific Language: Lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Jacumba Community Service District is responsible for providing high quality drinking water and removing lead pipes but cannot control the variety of materials used in plumbing components in your home. You share the responsibility for protecting yourself and your family from the lead in your home plumbing. You can take responsibility by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Before drinking tap water, flush your pipes for several minutes by running your tap, taking a shower, doing laundry or a load of dishes. You can also use a filter certified by an American National Standards Institute accredited certifier to reduce lead in drinking water. If you are concerned about lead in your water and wish to have your water tested, contact Jacumba CSD and Fernando Saenz, Chief Plant Operator, at 559-623-2457. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at <http://www.epa.gov/safewater/lead>.

About Your Drinking Water Quality

Drinking Water Contaminants Detected

Tables 1, 2, 3, 4, and 5 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The State Board allows us to monitor certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old. Any violation of an AL, MCL, MRDL, or TT is asterisked. Additional information regarding the violation is provided later in this report.

Table 1. Sampling Results Showing the Detection of Coliform Bacteria

Microbiological Contaminants	Highest No. of Detections	No. of Months in Violation	MCL	MCLG	Typical Source of Bacteria
<i>Coliform, Total</i>	Present	1	Absent	0	Naturally present in the environment

(a) The system tested positive for total coliform, a bacteria naturally present in soil, four times in April. The samples were further analyzed and E.coli, the fecal indicator bacteria, was absent.

Table 2. Sampling Results Showing the Detection of Lead and Copper

Contaminant	Sample Date	No. of Samples Collected	90 th Percentile Level Detected	No. Sites Exceeding AL	AL	PHG	Typical Source of Contaminant
Lead (ppb)	2023	17	ND	0	15	0.2	Internal corrosion of household water plumbing systems; discharges from industrial manufacturers; erosion of natural deposits
Copper (ppm)	2023	17	0.097	0	1.3	0.3	Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives

Table 3. Sampling Results for Sodium and Hardness

Constituent (reporting units)	Sample Date	Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Source of Contaminant
Sodium (ppm)	2023	73	N/A	None	None	Salt present in the water and is generally naturally occurring
Hardness (ppm)	2023	310	N/A	None	None	Sum of polyvalent cations present in the water, generally magnesium and calcium, and are usually naturally occurring

Table 4. Detection of Contaminants with a Primary Drinking Water Standard

Chemical or Constituent (reporting units)	Sample Date	Level Detected	Range of Detections	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Source of Contaminant
Barium (ppb)	2023	34	N/A	1000	2000	Discharges of oil drilling wastes and from metal refineries; erosion of natural deposits
Fluoride (mg/L)	2023	0.49	N/A	2	1	Erosion of natural deposits; water additive that promotes strong teeth; discharge from fertilizer and aluminum factories
Nitrate (ppm)	2024	0.36	N/A	10	10	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits.
Mercury (ppb)	2023	0.079	N/A	2	1.2	Erosion of natural deposits; discharge from refineries and factories; runoff from landfills and cropland
Selenium (ppb)	2023	0.64	N/A	50	30	Discharge from petroleum, glass, and metal refineries; erosion of natural deposits; discharge from mines and chemical manufacturers; runoff from livestock lots (feed additive)
Total Trihalomethanes (ppb)	2024	30	N/A	80	None	Byproduct of drinking water disinfection
Total Haloacetic Acids (ppb)	2024	3.4	N/A	60	None	Byproduct of drinking water disinfection
Uranium (pCi/L)	2024	1.07	N/A	20	0.43	Erosion of natural deposits
Chlorine (ppm)	2024	0.99	0.41 – 1.44	[4(as Cl ₂)]	[4(as Cl ₂)]	Drinking water disinfectant added for treatment

Table 5. Detection of Contaminants with a Secondary Drinking Water Standard

Chemical or Constituent (reporting units)	Sample Date	Level Detected	Range of Detections	SMCL	PHG (MCLG)	Typical Source of Contaminant
Iron (ppb)	2024	1300	ND - 1300	300	None	Leaching from natural deposits; industrial wastes
Manganese (ppb)	2024	470	ND - 470	50	None	Leaching from natural deposits
Specific Conductance ($\mu\text{S}/\text{cm}$)	2023	950	N/A	1,600	None	Substances that form ions when in water; seawater influence
Chloride (ppm)	2023	130	N/A	500	None	Runoff/leaching from natural deposits; seawater influence
Sulfate (ppm)	2023	140	N/A	500	None	Runoff/leaching from natural deposits; industrial wastes
Total Dissolved Solids (ppm)	2023	580	N/A	1000	None	Runoff/leaching from natural deposits

Table 6. Detection of Contaminants without a Drinking Water Standard

Chemical or Constituent (reporting units)	Sample Date	Level Detected	Range of Detections	Typical Source of Contaminant
Alkalinity (ppm)	2023	150	NA	Leaching from natural deposits; industrial wastes
Calcium (ppm)	2023	91.2	N/A	Leaching from natural deposits
Magnesium (ppm)	2023	19.5	N/A	Soil Runoff
pH (no units)	2023	7.5	N/A	Soil Runoff

Additional Information

2024 Lead Service Line Inventory (LSLI): The Lead and Copper Rule Revisions (LCRR) published by the U.S. Environmental Protection Agency (EPA) require all water systems to complete a lead service line inventory (LSLI) by October 16, 2024. A lead service line inventory was conducted in 2024. Pipes throughout the district were visually and physically inspected for the presence of lead. The district was found to have no lead service lines.